

Passive Recovery

- Passive recovery works best on small appliances (Type I).
 - Can be used on any Type I appliance (< 5 lb. refrigerant)
 - Not allowed on appliances with more than 15 lb. refrigerant
- No special devices are required for passive recovery
 - Use unit's compressor
 - Use an evacuated recovery container
 - Pack recovery container in cold water or dry ice (solid CO₂)
- Recovery into a "non-pressurized" container means a container under vacuum (< 0 psig)